Do not cover luminaire or driver with thermally insulating material (A). It is recommended to allow a minimum of 50 mm clearance above the luminaire as seen in (B).





V1-15.02.2024 Product designs and technical data may be subject to change

## Platinum P12Q Recessed Downlight

Installation Guide





Platinum P12Q

5

Trend Lighting Co. Pty Ltd



## For warranty information, please visit

trendlighting.com.au/warranty

## **Important Safety Information**

Please read these installation instructions carefully before installing this luminaire.

- This product must be installed by a licensed electrician in accordance with AS/NZS 3000 and local regulations.
- Isolate the mains power supply prior to installation.
- Only reconnect mains power after installation is completed.
- No part of the luminaire should be altered or modified.
- This product is not user serviceable.

2 Mark at the correct location. Cut a hole in the ceiling in accordance with cutout size. P12Q ceiling cutout: **76 mm** 

## Approvals

The RCM marking of this product applies to AS/NZS 4417.1 "Regulatory compliance mark (RCM) for electrical and electronic equipment". This product is designed to conform to AS/NZS 60598 "Luminaires, general requirements and tests".







Lift the springs upward to install the luminaire into the mounting hole.

